

BUILDING SAFETY CERTIFICATE

No. 1416 / NBC

Dated: 24-06-2025

Certified that the existing building MISSION ENGLISH SCHOOL (name of the building or premises) at M.F ROAD, CIVIL LINES BADAUN (address) comprised of GROUND FLOOR basement(s) and — (upper floors) owned/occupied by MISSION ENGLISH SCHOOL, CIVIL LINES BADAUN (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PUBLIC WORKS DEPARTMENT (Name of Department/ Govt.) on 24-06-2025 (date of inspection) in the presence of SHOBHA FRANCIS, MANAGING DIRECTOR M.E. SCHOOL (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes X (X/ XII) with effect from 24-06-2025 for a period of — years in accordance with rule and subject to compliance of the specific conditions as appended.

1. This building safety certificate is being issued for class-X grade.
2. The height of class rooms constructed at G.F complying norms of 3.50m
3. Fire fighting system is installed in school building premise
4. The width of school building corridor complying norms of 2.40 m

Issued on 24-06-2025 at CD-2, PWD Badaun by

* Strike out whichever is not applicable.

सहायक अभियन्ता
नि० खण्ड नं० 2 लो० नि० वि०

Signature with Seal :

Name : ER. MUNISH KUMAR

Designation : ASSISTANT ENGINEER (CIVIL)

Name & Address of Department/ Office: CD-2, PWD BADAUN

(Assistant Engineer & above officer of concerned Govt. Department only)



Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.